



## City of East Lansing Fire Prevention Bureau

1700 Abbot Road

East Lansing, MI 48823

Office 517-332-1956 Fax 517-337-1112

fireprevention@cityofeastlansing.com

### **OUTDOOR FIRES AND CONTAINED OUTDOOR FIRES**

Pursuant to City Ordinance No. 1493, Chapter 16, FIRE PREVENTION AND PROTECTION, Section 307 of the fire code as amended, the following regulations are hereby promulgated by the Fire Marshal upon approval of City Council:

NOW THEREFORE, IT IS RESOLVED that the City Council of the City of East Lansing hereby adopts the following regulations as promulgated by the Fire Marshal for outdoor fires and contained outdoor fires:

#### **Contained Outdoor Burning Regulations**

- \*An annual permit must be first obtained pursuant to section 105.6 of the Fire Prevention Code
- \*Fire permits are only available in areas zoned as R-1 and R-2. If the property is NOT owner-occupied, you must have permission from the landlord.
- \*The fire must be continuously attended.
- \*A water source must be available for immediate utilization.
- \*Burning of building materials, non-wood items and rubbish is strictly prohibited.
- \*A recreational fire pit shall not be operated within 25 feet of a structure, property line, driveway, roadway or combustible material (including decks, sheds and fences). Recreational fire pits must be covered by a spark arresting screen.
- \*Portable outdoor fireplaces shall not be operated within 15 feet of a structure, property line, driveway, roadway or combustible material (including decks, sheds and fences). This includes liquid petroleum gas fireplaces.
- \*The container must be located on a non-combustible surface.
- \*Fires will not be permitted when wind speed is greater than 15 miles per hour, or during a state ban on fires in the area.
- \*Size requirements – total fuel area must be 3 feet or less in diameter and 2 feet or less in height (exclusive of chimneys and legs). The container may be built but must be enclosed at all times for recreational purposes but does not have to be enclosed if going to be used for cooking.
- \*The container must be free of rust or corrosion which affects the integrity of the container. The owner is responsible for inspecting the container prior to each fire as to its integrity.
- \*When open burning creates or adds to a hazardous situation, or a required permit for open burning has not been obtained, the fire code official is authorized to order the extinguishment of the open burning operation.
- \*Any permit may be revoked or denied by the Fire Prevention Bureau pursuant to section 105.5 of the Fire Prevention Code